



**RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**  
**Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.**  
**NABL Accredited Laboratory Bangalore urban**

TEST REPORT					
<b>Address of the sampling location : Deens Academy</b>  Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2 Kathriguppe Village, Sarjapura Hobli, Anekal Taluk Bengaluru				Report date: 31/07/2025	
				Report Number: 015	
				Reference: TRF	
				Sample code: 015	
				Date of Sample collection: 29/07/2025	
				Analysis start date: 30/07/2025	
				Analysis completion date: 31/07/2025	
				Sample quantity: 1 Liter	
Sample Particulars: R O water					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.0	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, µS/cm @25°C Temp	120	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	70	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO <sub>3</sub> , mg/l	20.9	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO <sub>3</sub> , mg/l	20.4	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	5.0	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	13.9	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO <sub>4</sub> , mg/l	9.1	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	0.2	1	1.5	APHA 24 <sup>th</sup> Edition
14	Nitrate as NO <sub>3</sub> , mg/l	3.3	45	No relaxation	APHA 24 <sup>th</sup> Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the Acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: Megha K. S Senior Analyst/Junior Analyst				Authorized Signatory: Pavithra B.S Technical Manager: Pavithra B.S	




RDWSD/WQMSP/TeR/01

**Note:**

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---



*Pavithra*

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**

No. 015

Date :31-07-2025

It is certified that an inspection team headed by Pavithra B S Sr. Analyst RDWSD (Name of Officers with designation) from RDWSD District Laboratory Bangalore (Name of Department/ Office) inspected **Deens Academy**, Bangalore (Name of school) on 29-07-2025 and the basis of Water Test Report number 15 dated 31-07-2025 of RDWSD District Laboratory Certified that the **Deens Academy**, Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2 Kathriguppe Village, Sarjapura Hobli, Anekal Taluk, Bengaluru (Name & Address of the School) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 30-07-2026

Signature with Seal : Pavithra B S  
Rural Drinking Water  
Testing District LaboratoryName Pavithra B SDesignation Sr. AnalystName & Address of the Department: RDWSD Division  
Bengaluru

TO

Deens Academy

Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2

Kathriguppe Village,

Sarjapura Hobli, Anekal Taluk

Bengaluru



*Shanthi*