

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. 0004Date : 10-08-2026

It is certified that an inspection team headed by Pavithra B S Sr. Analyst RDWSD (Name of Officers with designation) from RDWSD District Laboratory Bangalore (Name of Department/ Office) inspected **Deens Academy**, Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2 kathriguppe Village, Sarjapura Hobli, Anekal Taluk, Bengaluru (Name & Address of the School) on 06-08-2026 and the basis of Water Test Report number 0004 dated 10-08 -2026 of RDWSD District Laboratory Certified that the **Deens Academy**, Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2 kathriguppe Village, Sarjapura Hobli, Anekal Taluk, Bengaluru has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 09-08-2027

Signature with Seal : Rural Drinking Water
Testing District Laboratory

Name :

Designation :

Pavithra B S
Chemist
Pavithra B S
Bengaluru
Sr. Analyst

Name & Address of the Department: RDWSD Division

Bengaluru


To

Deens Academy,

Sy No. 48/2,48/3, 48/4, 49/1, 51/2, 52 and 56/2

kathriguppe Village, Sarjapura Hobli,

Anekal Taluk, Bengaluru



Shanthy

Shanthy



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.

NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location : Deens Academy,
 Sy No, 48/2, 48/3, 48/4, 49/1, 51/2, 52 and 56/2
 Kathriguppe Village, Sarjapura Hobli,
 Anekal Taluk, Bengaluru.

Report date: 10/08/2026
 Report Number: 0004
 Reference: TRF
 Sample code: 0004
 Date of Sample collection: 06/08/2026
 Analysis start date: 06/08/2026
 Analysis completion date: 07/08/2026

Sample Particulars: R O water

Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.9	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	100	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	60	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	12.6	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	16.0	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	3.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	1.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	13.6	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	5.0	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	3.0	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	<0.1	1	No relaxation	IS 3025 (Part-53) : 2003

Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.

Analyzed by: *Megha K.S.*
 Senior Analyst/Junior Analyst

Authorized Signatory: *Pavithra B.S.*
 Technical Manager: Pavithra B.S.



RDWSD/WQMSP/TeR/01

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---